

INSTALLATION INSTRUCTIONS 3, 4, 6 AND 8 INCH METER

ALL 3, 4, 6, 8 INCH METERS OPERATE MORE ACCURATELY AND RELIABLE IF INSTALLED PROPERLY. WE ARE CURRENTLY USING THE NEPTUNE MACH 10 900i ULTRASONIC METER FOR ALL INSIDE AND VAULT APPLACATIONS.

ALL METERS SHOULD BE PLUMBED AND INSTALLED IN AN AREA THAT IS ACCESSIBLE AT ALL TIMES AND MUST HAVE APPROVED BACKFLOW DEVISE DIRECTLY BEHIND METER AND TESTED WITHIN 30 DAYS. WITH RESULTS SENT TO: CARMEL UTILITIES 3450 W. 131ST ST. CARMEL, IN. 46032

THE OPENING BETWEEN INCOMING GATE VALVE FLANGE AND OUTGOING GATE VALVE FLANGE IS 45 ½" (THIS METER APLICATION DOES NOT REQUIRE A STRAINER)

THE METER SET NEEDS TO BE HORIZONTAL NOT VERTICAL.

THE METER SET NEEDS TO BE A MINIMUM OF 24" OFF THE FLOOR, MAX HEIGHT OF 48" AND A MINIMUM OF 24" FROM WALL OR ANY OBSTRUCTION.

ALL VALVES MUST BE OS&Y. MUELLER OR AMERICAN. VALVES SHALL BE OPEN RIGHT

CARMEL UTILITIES WILL PROVIDE THE NUTS, BOLTS AND GASKETS FOR INSTALLATION.

FOR A MULTIPLE METER INSTALLATION. PLEASE CONTACT CARMEL UTILITIES FOR APPROVAL.

