



NOTE:

- 1) 1" Or Smaller Service Line Shall Be Direct Tap Unless Approved By Carmel Utilities.
- 2) Corporation Stop Shall Be Brand And Model Approved By Carmel Utilities.
- 3) Service Line Tap Shall Be Installed With A Min. Horiz. Separation of 24".
- 4) 2 Inch Taps And Smaller Shall Not Be Installed Within 18 Inches of Mechanical Joints And Bells.
- 5) No Meter Pits Allowed in Areas Sidewalks, Driveways, Roads, Etc.
- 6) Granular Backfill Required Around All Meter Pits With 6" Topsoil
- 7) Short Side Services Require Type K-Copper
Long Side Services Require Poly SDR9 With Tracer Wire (Only with Carmel Utilities Approval)
- 8) No Service Tap shall be under Any Part of the Drive Way. Taps under Drive Ways Shall be Abandoned and Re-Tapped Away from Driveway. Abandoned Tap will be Removed and Repair Clamp Placed.



3450 W. 131st. Street
Carmel, IN 46074

Phone: 317-733-2855
Fax: 317-733-2053

CARMEL WATER
STANDARD DETAILS

TITLE:
RESIDENTIAL WATER SERVICE
WITH IRRIGATION HOOKUP

Date: January 2023	Scale: No Scale	Drawn By: Crossroad Engineers	Drawing Name: CW-2
-----------------------	--------------------	----------------------------------	-----------------------