



* Service Saddle Must Be Omitted For Services 1" And Smaller And Direct Taps Made to Ductile Iron Pipe, Class 350 Or Greater. (Verify With Owner For Pressure Class DIP.)

- NOTE:**
- 1) 1" Or Smaller Service Line Shall Be Direct Tap Unless Approved By Carmel Utilities.
 - 2) Corporation Stop Shall Be Brand And Model Approved By Carmel Utilities.
 - 3) Service Line Tap Shall Be Installed With A Min. Horiz. Separation of 24".
 - 4) No Meter Pits Allowed in Areas Sidewalks, Driveways, Roads, Etc.
 - 5) Granular Backfill Required Around All Meter Pits With 6" Topsoil
 - 6) Short Side Services Require Type K-Copper Long Side Services Require Poly SDR9 With Tracer Wire (Only with Carmel Utilities Approval)
 - 7) No Service Tap shall be under Any Part of the Drive Way. Taps under Drive Ways Shall be Abandoned and Re-Tapped Away from Driveway. Abandoned Tap will be Removed and Repair Clamp Placed.



3450 W. 131st. Street
Carmel, IN 46074

Phone: 317-733-2855
Fax: 317-733-2053

CARMEL WATER
STANDARD DETAILS

TITLE:
RESIDENTIAL WATER SERVICE
WITH CURB STOP DETAIL

Date: January 2023

Scale: No Scale

Drawn By: Crossroad Engineers

Drawing Name: CW-4