



PLAN

NOTES:

- 1) RESTRAIN PIPE PER JOINT RESTRAINT TABLE
- 2) ALL WATER MAIN CONNECTIONS ARE TO BE APPROVED BY CWU PRIOR TO WORK
- 3) CONTRACTOR TO SCHEDULE OUTAGES WITH CWU 3 DAYS PRIOR TO OUTAGE
- 4) THIS DRAWING IS A SIMPLIFIED DETAIL. MORE FITTINGS MAY BE REQUIRED ONCE ACTUAL LOCATION ELEVATIONS HAVE BEEN VERIFIED BY CONTRACTOR
- 5) CONTRACTOR MUST COORDINATE WITH CWU ON WHICH RELOCATIONS MUST UNDERGO PRESSURE TESTING AND WATER QUALITY TESTING
- 6) PREFORMED THRUST BLOCKS ARE REQUIRED.



3450 W. 131st. Street  
Carmel, IN 46074

Phone: 317-733-2855  
Fax: 317-733-2053

CARMEL WATER  
STANDARD DETAILS

TITLE: WATER MAIN  
CONNECTION AND  
HORIZONTAL RELOCATION

Date:	January 2023	Scale:	No Scale	Drawn By:	Crossroad Engineers	Drawing Name:	CW-43
-------	--------------	--------	----------	-----------	---------------------	---------------	-------