



**NOTES:**

1. All pipe to be restrained joint.
2. Pipe is to be ductile iron, minimum pressure class 350.
3. Bottom of lowering shall be centered on conflict, and shall be a solid piece of pipe with no joints or fittings under the existing pipe or conflict.



3450 W. 131st. Street  
Carmel, IN 46074

Phone: 317-733-2855  
Fax: 317-733-2053

CARMEL WATER  
STANDARD DETAILS

TITLE:  
WATER MAIN  
LOWERING

Date: January 2023

Scale: No Scale

Drawn By: Crossroad Engineers

Drawing Name: CW-44