



* Service Saddle Must Be Omitted For Services 1" And Smaller And Direct Taps Made to Ductile Iron Pipe, Class 350 Or Greater. (Verify With Owner For Pressure Class DIP.)

NOTE:

- 1) 1" Or Smaller Service Line Shall Be Direct Tap Unless Approved By Carmel Utilities.
- 2) Corporation Stop Shall Be Brand And Model Approved By Carmel Utilities.
- 3) Service Line Tap Shall Be Installed With A Min. Horiz. Separation of 24".
- 4) No Meter Pits Allowed in Areas Sidewalks, Driveways, Roads, Etc.
- 5) Granular Backfill Required Around All Meter Pits With 6" Topsoil
- 6) Short Side and Long Side Services Require Type K-Copper Long Side Services Require Poly SDR9 With Tracer Wire Poly Services with Tracer Wire only Allowed for Long Side Services over 100 LFT and if Approved by Carmel Water
- 7) No Service Tap shall be under Any Part of the Drive Way. Taps under Drive Ways Shall be Abandoned and Re-Tapped Away from Driveway. Abandoned Tap will be Removed and Repair Clamp Placed.
- 8) 5' of Copper Outside of Pit to Connect to Customer Line



3450 W. 131st. Street
Carmel, IN 46074

Phone: 317-733-2855
Fax: 317-733-2053

CARMEL WATER
STANDARD DETAILS

TITLE:

COMMERCIAL WATER
SERVICE DETAIL

Date: January 2023

Scale: No Scale

Drawn By: Crossroad Engineers

Drawing Name: CW-5